


Evidence of performance
Airborne sound insulation of building components

Test Report

No. GLA-1312.3/17 E

Client**PRESS GLASS S.A.**Nowa Wieś
ul. Kopalniana 9
42-262 Poczesna

Product:	Insulating glass unit
Construction:	8/16/6/16/12,76
Designation:	TH1,1 8/16/FL 6/16/66.2 TH1,1 kl.P2A U=0,6 EN673 Ar
Dimension:	1230 mm x 1480 mm
Gas filing:	Argon
Area related mass	67 kg/m ²
Cross-section:	

Rating	R _w (C; C _{tr})	STC	OITC
Basis	EN ISO 10140-1:2010 EN ISO 10140-2:2010 EN ISO 717-1: 2013	ASTM E413-10	ASTM E1332-10
Value	45 (-1; -5) dB	45 dB	30 dB

Łozienica, 10.04.2017


PhD Krzysztof Mech
Head of Acoustics Laboratory