


**Evidence of performance  
Airborne sound insulation of building components**

Test Report

No. GLA-1312.4/17 E

Client**PRESS GLASS S.A.**Nowa Wieś  
ul. Kopalniana 9  
42-262 Poczesna

Product:	Insulating glass unit
Construction:	8/16/6/16/12,76 aku
Designation:	TH1,1 8/16/FL 6/16/66.2 TH1,1 Phon. kl.P2A U=0,6 EN673 Ar
Dimension:	1230 mm x 1480 mm
Gas filing:	Argon
Area related mass	67 kg/m <sup>2</sup>
Cross-section:	

Rating	R <sub>w</sub> (C; C <sub>tr</sub> )	STC	OITC
Basis	EN ISO 10140-1:2010 EN ISO 10140-2:2010 EN ISO 717-1: 2013	ASTM E413-10	ASTM E1332-10
Value	<b>46 (-2; -6) dB</b>	<b>46 dB</b>	<b>32 dB</b>

Łozienica, 24.04.2017

  
**PhD Krzysztof Mech**  
Head of Acoustics Laboratory