


Evidence of performance Airborne sound insulation of building components

Based on the Test Report: **No. GLA-1364/18 E**

Client

PRESS GLASS S.A.

Nowa Wieś
ul. Kopalniana 9
42-262 Poczesna

Product:	Insulating glass unit
Construction:	8,76 aku/16/6,76
Designation:	44.2 Phon kl.P2A/16/33.2 TH1,1 kl.P2A Ar
Dimension:	1230 mm x 1480 mm
Gas filing:	Argon
Area related mass	39 kg/m ²
Cross-section:	

Rating	R _w (C; C _{tr})	STC	OITC
Basis	EN ISO 10140-1:2016 EN ISO 10140-2:2010 EN ISO 717-1: 2013	ASTM E413-16	ASTM E1332-16
Value	41 (-2; -6)dB	41 dB	32 dB

Łozienica, 06.03.2018



PhD Krzysztof Mech
Head of Acoustics Laboratory