

Evidence of performance


Airborne sound insulation of building components

Based on the Test Report: **No. GLA-1378.2/18 E**

Client

PRESS GLASS S.A.

Nowa Wieś
ul. Kopalniana 9
42-262 Poczesna

Product:	Insulating glass unit
Construction:	12,76/16/4/18/23,04
Designation:	VSG (FL 6/0,76 PVB/TH 1,1 6) kl.1/B/1/16/FL 4/18/VSG (23,04 kl.P7B TH 1,1) kl.1/B/1 U=0,5 EN673 Ar
Dimension:	1230 mm x 1480 mm
Gas filing:	Argon
Area related mass	91 kg/m ²
Cross-section:	

Rating	R _w (C; C _{tr})	STC	OITC
Basis	EN ISO 10140-1:2016 EN ISO 10140-2:2010 EN ISO 717-1: 2013	ASTM E413-16	ASTM E1332-16
Value	49 (-2; -4)dB	49 dB	39 dB

Łozienica, 30.05.2018

PhD Krzysztof Mech
Head of Acoustics Laboratory