


Evidence of performance Airborne sound insulation of building components

Based on the Test Report: **No. GL1402 / 18 E**

Client

PRESS GLASS S.A.

Nowa Wieś
ul. Kopalniana 9
42-262 Poczesna

Product:	Insulating glass unit
Construction:	8,76acoust./ 16 / 8,76acoust.
Designation:	VSG (FL 4/0,76 PVB SC/Combi Neutral 70/40 4) kl.1/B/1 / 16 / 44.2 Phon kl.P2A U=1,1 EN673 Ar
Dimension:	1230 mm x 1480 mm
Gas filling:	Argon
Area related mass	41,4 kg/m ²
Cross-section:	

Rating	R _w (C; C _{tr})	STC	OITC
Basis	EN ISO 10140-1:2016 EN ISO 10140-2:2010 EN ISO 717-1: 2013	ASTM E413-16	ASTM E1332-16
Value	45 (-3; -8)dB	45 dB	34 dB

Łozienica, 23.10.2018

dr Krzysztof Mech
Kierownik Laboratorium Akustyki