


Evidence of performance Airborne sound insulation of building components

Based on the Test Report: No. GLA-1426.3 / 18 E

Client

PRESS GLASS S.A.

Nowa Wieś
ul. Kopalniana 9
42-262 Poczesna

Product:	Insulating glass unit
Construction:	8 / 16 / 10,76 aku
Designation:	TH1,1 8/16/VSG (FL 5/0,76 PVB SC/FL 5) kl.1/B/1 U=1,1 EN673 Ar
Dimension:	1230 mm x 1480 mm
Gas filing:	Argon
Area related mass	--- kg/m ²
Cross-section:	

Rating	R _w (C; C _{tr})	STC	OITC
Basis	EN ISO 10140-1:2016 EN ISO 10140-2:2010 EN ISO 717-1: 2013	ASTM E413-16	ASTM E1332-16
Value	42 (-3; -8)dB	41 dB	31 dB

Łozienica, 28.01.2018

dr Krzysztof Mech
Kierownik Laboratorium Akustyki